REVISIONS			
REV.	DESCRIPTION	DATE	APPROVED
A	FLANGE WAS 40NB JIS 10	5/02/2025	NDB
B	FLANGE WAS 40NB-PN16 & 40NB TABLE H	10/02/2025	NDB

ITEM	DRAWING No	DESCRIPTION	QTY.	MASS (kg)
1	OEM-40-SR-40-316L	40NB SHORT RADIUS BEND 316L S/S SHED 40	1	0.25
2	OEM-40-LR-40-316L	40NB LONG RADIUS BEND 316L S/S SHED 40	1	0.37
3	OEM-40-150-SO-M-316L	40NB FLANGE ANSI 150 LB SLIP ON HOLES SLOTTED 316L S/S	1	1.3
4	OEM-40-150-SO-316L	40NB FLANGE ANSI 150 LB SLIP ON 316L S/S	1	1.3
5	3435-50-014-03	PIPE LABEL W-014	1	0.01
6	3435-50-014-02	40NB SHED 40 316 S/S PIPE	1	0.47
7	3435-50-014-01	40NB SHED 40 316L S/S 1250 R	1	6.57

RED EYE QR CODE AREA

AS INSTALLED 14/3/25

PIPEWORK MANUFACTURED OF A JIG - FLANGES AS PER DRAWING
DIMENSIONS ARE APPROXIMATE

PIPE W-014 ASSEMBLY WEIGHT - 9.52 kg

ALL WELDS - 4 CFW UNLESS NOTED OTHERWISE

REV	NAME & DATE	DESCRIPTION

UNLESS OTHERWISE SPECIFIED:
TOLERANCES: MACHINE + / - 0.25mm
FABRICATION + / - 1.0 mm

THIS DRG SUPPLIED BY
RODDY ENGINEERING
14 Waratah St, TUMUT NSW 2720
Ph: 02 6947 4039

DRAWING No. 3435-50-014 REV: B

DRAWN N DE BRUYN 30/04/2024
DRAWING CHECKED
DESIGNED
DESIGN CHECKED
SCALE 1:5
WORK ORDER No
APPROVED
SECTION No/KKS
A2 SHEET SIZE

snowyhydro LIMITED

M2 POWER STAION
UNIT 11 TURBINE COOLING WATER
PIPE W-014 ASSEMBLY

SMA-DRG-NO | B | REV | SHEET 1 OF 1