**NOTES:**
- Flanges are to be welded and inspected in accordance with SHL-MEC-119
- All bare metal surfaces are painted in accordance with SHL-GEN-123
- All modified pipework shall be pressure tested and cleaned internally as per SHL-MEC-119
- Pipework shall be setup in work shop as per site installation prior to welding new flanges

| ITEM | DRAWING No | DESCRIPTION | QTY. | MASS (kg) |
|---|---|---|---|---|
| 1 | 3963-30-20 | 50x3 SHS-PIPE SUPPORT BRACKET | 1 | 2.74 |
| 2 | 3963-30-10 | MOUNT PLATE - PIPE SUPPORT BRACKET | 1 | 4.33 |

**FINISH** - ETCH PRIMER &
2 COATES ZINC RICH PAINT

PIPE SUPPORT BRACLET TYPE 1 WEIGHT - 7.07 kg

| REV | NAME & DATE | DESCRIPTION |
|---|---|---|

UNLESS OTHERWISE SPECIFIED:
TOLERANCES: MACHINE + / - 0.25mm
FABRICATION + / - 1.0 mm

THIS DRG SUPPLIED BY
RODDY ENGINEERING
14 Waratah St, TUMUT NSW 2720
Ph: 02 6947 4039

DRAWING No. 3963-30
REV:

DRAWN N DE BRUYN 8/07/2025
DRAWING CHECKED
DESIGNED N DE BRUYN 21/07/2025
DESIGN CHECKED
SCALE 1:5
WORK ORDER No
APPROVED K. CALLAGHAN 8/07/2025
SECTION No/KKS
A3 SHEET SIZE

snowyhydro LIMITED

BLOWERING POWER STATION
GOVENOR PUMPING SET
GUIDE MOTOR CLOSING
PIPE SUPPORT BRACKET TYPE 1 DETAIL

**SK-7596**

REV

SHEET 1 OF 1

0,0