NOTES:
- Flanges are to be welded and inspected in accordance with SHL-MEC-119
- All bare metal surfaces are painted in accordance with SHL-GEN-123
- All modified pipework shall be pressure tested and cleaned internally as per SHL-MEC-119
- Pipework shall be setup in work shop as per site installation prior to welding new flanges

ITEM	DRAWING No	DESCRIPTION	QTY.	MASS (kg)
1	3963-35-20	50x3 SHS-PIPE SUPPORT BRACKET	1	3.22
2	3963-30-10	MOUNT PLATE - PIPE SUPPORT BRACKET	1	4.33

FINISH - ETCH PRIMER &
2 COATES ZINC RICH PAINT

PIPE SUPPORT BRACLET TYPE 2 WEIGHT - 7.55 kg

REV	NAME & DATE	DESCRIPTION

UNLESS OTHERWISE SPECIFIED:
TOLERANCES: MACHINE + / - 0.25mm
FABRICATION + / - 1.0 mm

THIS DRG SUPPLIED BY
RODDY ENGINEERING
14 Waratah St, TUMUT NSW 2720
Ph: 02 6947 4039

DRAWING No. 3963-35 REV:

DRAWN N DE BRUYN 8/07/2025
DRAWING CHECKED
DESIGNED N DE BRUYN 21/07/2025
DESIGN CHECKED
SCALE 1:5
WORK ORDER No
APPROVED K. CALLAGHAN 8/07/2025
SECTION No/KKS
A3 SHEET SIZE

snowyhydro LIMITED

BLOWERING POWER STATION
GOVENOR PUMPING SET
GUIDE MOTOR CLOSING
PIPE SUPPORT BRACKET TYPE 2 DETAIL

SK-7597

REV

SHEET 1 OF 1

0,0